



Hotel Las Vegas (H**)

Accommodation — Hotels / Apartment hotels / Hostels / Guesthouses



 **Street**


Calle de Vitoria, 319 09007
Burgos, Burgos (Castilla y León)
Spain

 **Contact**

Tel 947 484 453
reservas@hotelasvegas.com
<http://www.hotelasvegas.es/>

 **Created by**

Andrés Díez 10/01/2017

 **Last modification by**

Andrés Díez 10/01/2017



Information about the accessibility of this tourist resource has been provided by users

General Information

El hotel está en las afueras de la ciudad. Puedes llegar en autobús y en coche propio. El hotel es un edificio moderno. El hotel tiene 5 plantas. En la planta baja está la recepción, una sala de reuniones, el bar, el restaurante y los cuartos de baño comunes. En la planta 1 están los cuartos de baño adaptados, 2 salas de reuniones y varias habitaciones

Entrance



Entrance: No slopes

✓ Name of the tourist resource clearly visible and legible

The entranceway analysed is: The main one

Width of the entrance door: Greater than or equal to 78 cm

Customer Service Area

✓ Customer service desk

Characteristics



✓ Near the entrance

Inside circulation

Wheelchair circulation: Total

Adequate lighting: Yes

✓ Without elements that can suppose an obstacle for a person with a visual disability

Signposting: Yes

Characteristics

Signs: With colour-contrasted texts

✓ Establishment with more than one floor

Vertical itinerary

Transit between floors via: Lift / lifts, steps / stairs

Lift information

Dimensions of the cubicle: Medium

✓ With visual information

✓ Lift buttons at a suitable height for wheelchair users

Stair information

Number of steps: More than 3

Height of the step in cm: 19

✓ Hand rail

Adapted room

✓ Room adapted for people with a physical disability

Characteristics



Number of adapted rooms: 3

Number / name of the room: 442

Comfortable circulation to the room: Yes

Door width : Greater than or equal to 78 cm

Manoeuvre area with a diameter greater than or equal to 150 cm: Yes

Space to the side of the bed: Yes

Information

The space is at least 90 cm or greater: On the right-hand side

Height of the bed in cm (including mattress): 48

Bathroom



Access without differences in height: Yes

Door width: Greater than or equal to 78 cm

Door opening: Inward

Free turning space ? 150 cm of diameter: No

Clear space to transfer to the toilet: Yes

Characteristics

The space is at least 80 cm or greater: Right-hand side

Height of the toilet seat: Standard (between 40 and 45 cm)

Toilet next to the shower: No

There are grab bar(s): Yes

Information

Toilet grab bars: Right-hand side, left-hand side

The bars on the left-hand side are: Fixed

The bars on the right-hand side are: Fixed

Sink: With mixer tap, without pedestal

✓ Bath

Characteristics

Space greater than or equal to 80 cm approach: Yes

Grab bar(s) in the bath: Yes

Mixer water tap: Yes

Height-adjustable shower head: Yes

Approved bath seat: Yes

✓ Room adapted for people with a visual disability

Characteristics

✓ Comfortable circulation to the room

✓ Big and of contrasting colour room number

✓ Doors of contrasting colour

✓ Without elements that can suppose an obstacle for a person with a visual disability

✓ Room adapted for people with an auditory disability

Restaurant and bar areas

Counter at a height adapted for a person in a wheelchair: No

Menu with big texts and contrasting colour: No

✓ Table service available

Accessible tables: Yes

Adapted toilet in common areas

✓ Toilet suitable for PRM

Characteristics

Access without changes in floor level: Yes

Door width: Greater than or equal to 78 cm

Door opening: Inward

Free turning space ? 150 cm of diameter: No

Clear space to transfer to the toilet: Yes

Characteristics

The space is at least 80 cm or greater: Right-hand side

Height of the toilet seat: Standard (between 40 and 45 cm)

It has support bar(s): Yes

Information

Toilet grab bars: Right-hand side

The bars on the right-hand side are: Folding

Sink: Without pedestal

Services and amenities

Sufficient information provided about accessibility to the tourist resource : No

Magnetic induction loop: No

✓ Customer service staff

Staff training

Personal trained in attention to people with disabilities : No

Personal available to support people with specific needs: No

Personal with knowledge of Sign Language: No

Outside areas

Sidewalks: Without obstacles

Uniform and anti-slip pavement: Yes

Rating of establishment / place of interest

Rate 1 to 5 general accessibility of the establishment: 3 - Average