



# ZENIT EL POSTIGO

Accommodation — Hotels / Apartment hotels / Hostels / Guesthouses



## 📍 Street

C/ El Postigo, 5 23400  
Úbeda, Jaén (Andalucía)  
Spain

## ☎ Contact

Tel 953 750 000  
reservaselpostigo@grupozenithoteles.com  
<https://elpostigo.zenithoteles.com>

## 📅 Created by

PREDIF Técnico 3 03/04/2018

## 📅 Last modification by

PREDIF Técnico 3 31/07/2018



The accessibility of this tourism resource has been analyzed by experts

## General Information

Una de las puertas del recinto amurallado que en su día rodeó la ciudad antigua y que se hallaba a escasos metros presta su nombre al Hotel El Postigo. Situado en el centro histórico de Úbeda sus muros empedrados y sus blancas fachadas parecen brindarnos una maravillosa paradoja entre este singular hotel y el entorno en el que se encuentra. La adecuada sencillez en la arquitectura, el diseño sobrio y elegante, la templanza en los colores, la máxima comodidad y la última tecnología que inspiran y se respiran en cada espacio del hotel y el monumental Renacimiento andaluz que se alza, imponente, en su exterior a cada paso.

## Entrance

Entrance: Inclined plane / ramp

### Ramp information

The slope makes the ramp : Can be used autonomously

- ✓ Name of the tourist resource clearly visible and legible

The entranceway analysed is: The main one

Width of the entrance door: Greater than or equal to 78 cm

Obstacles at the doorway: Glass door without visual warning markers

## Customer Service Area

- ✓ Customer service desk

### Characteristics



- ✓ Near the entrance
- ✓ Height suitably adapted for wheelchair users

## Inside circulation

Wheelchair circulation: Total

Adequate lighting: Yes

- ✓ Without elements that can suppose an obstacle for a person with a visual disability

Signposting: Yes

- ✓ Establishment with more than one floor

### Vertical itinerary

Transit between floors via: Lift / lifts, steps / stairs

#### Lift information

Dimensions of the cubicle: Big

- ✓ With visual information

Lift buttons: Of contrasting colour

- ✓ Lift buttons at a suitable height for wheelchair users

#### Stair information

Number of steps: More than 3

Height of the step in cm: 17

- ✓ Hand rail

## Adapted room

- ✓ Room adapted for people with a physical disability

### Characteristics



Number of adapted rooms: 1

Number / name of the room: 201

Comfortable circulation to the room: Yes

Door width : Greater than or equal to 78 cm

Manoeuvre area with a diameter greater than or equal to 150 cm: Yes

Space to the side of the bed: Yes

### Information

The space is at least 90 cm or greater: On the left-hand side

Height of the bed in cm (including mattress): 53

### Bathroom



Access without differences in height: Yes

Door width: Greater than or equal to 78 cm

Door opening: Outward

Free turning space ? 150 cm of diameter: Yes

Clear space to transfer to the toilet: Yes

### Characteristics

The space is at least 80 cm or greater: Left-hand side, right-hand side

Height of the toilet seat: Standard (between 40 and 45 cm)

Toilet next to the shower: Yes

There are grab bar(s): Yes

### Information

Toilet grab bars: Left-hand side, right-hand side

The bars on the left-hand side are: Folding

The bars on the right-hand side are: Folding

Sink: With mixer tap, without pedestal

✓ Bath

#### Characteristics

Space greater than or equal to 80 cm approach: Yes

Grab bar(s) in the bath: No

Mixer water tap: Yes

Height-adjustable shower head: Yes

Board of transference: No

Approved bath seat: No

✓ Room adapted for people with a visual disability

#### Characteristics

✓ Comfortable circulation to the room

✓ Big and of contrasting colour room number

✓ Doors of contrasting colour

✓ Without elements that can suppose an obstacle for a person with a visual disability

✓ Switches and sockets of contrasting colour

✓ Room adapted for people with an auditory disability

#### Characteristics

✓ Internet connection

✓ Written information of the services

## Restaurant and bar areas

Counter at a height adapted for a person in a wheelchair: No

✓ Menu for people with special dietary needs (celiac disease, diabetes, allergies,...)

✓ Table service available

Accessible tables: Yes

## Adapted toilet in common areas

- ✓ Toilet suitable for PRM

### Characteristics

Access without changes in floor level: Yes

Door width: Greater than or equal to 78 cm

Door opening: Inward

Free turning space ? 150 cm of diameter: Yes

Clear space to transfer to the toilet: Yes

### Characteristics

The space is at least 80 cm or greater: Right-hand side

Height of the toilet seat: Standard (between 40 and 45 cm)

It has support bar(s): Yes

### Information

Toilet grab bars: Left-hand side, right-hand side

The bars on the left-hand side are: Fixed

The bars on the right-hand side are: Folding

Sink: With mixer tap, without pedestal

## Services and amenities

Sufficient information provided about accessibility to the tourist resource : Yes

Magnetic induction loop: No

- ✓ Customer service staff

### Staff training

Personal trained in attention to people with disabilities : No

Personal available to support people with specific needs: No

Personal with knowledge of Sign Language: No

## Outside areas

Sidewalks: Without obstacles

Uniform and anti-slip pavement: Yes